

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Sunday, March 06, 2016 1:52 PM
To: Burns, David (DEP); Turin, David
Cc: Dow, James; Frank Cavaleri; Kevin Stetson; Steve Isaac; Mark Cleary; Tokadjian, Panos
Subject: Planned plant power shutdown - Hull Wastewater Plant - MA0101231 - March 9, 2016

Gentlemen:

Confirming – as weather forecast currently looks favorable for 3/9/16 and plant flows are reasonable at <2MGD during the shutdown period.

The Hull wastewater facility is planning a power shutdown this upcoming Wednesday, March 9th, weather permitting, in order to perform electrical preventive maintenance on the main switchgear and main breakers. Also, current trip settings will be adjusted per the recent Arc Flash study that was completed on the main breakers. The project is being co-ordinated with the Hull Municipal Light Dept, EESCO, and facility staff. During the time of the shut down, the emergency generators will be off line. Influent sewage will be pumped into the off-line tanks – one primary clarifier, two aeration tanks, and one secondary clarifier. The wastewater will be held until power is restored and be pumped back into the plant when power is restored.. The off-line capacity [0.85 MG] will provide approximately 8-10 hours of detention time at flow rate of 2.0-2.5 MG, and the preventive maintenance work will take about 6 hours to complete. No untreated wastewater will leave the facility.

Influent pumping will be done with the Godwin pump that is currently set up as an emergency pump at the influent wet well, and there will be additional portable pumps set up, in case needed, on the influent and effluent wet wells.

Should plans be changed due to weather or unanticipated higher flows, will inform keep you informed, and I will inform you when the testing is completed, and the plant back on line.

Please let me know if you have any concerns or questions.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS